



# Emery RC Lead in Water Test Results

## FY21 Filter Test

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005485	5/14/2020	5/14/2021	2	Cooler	In hallway across from elevator	High Left	WF-05142020-005485	3/10/2021	FT-FY21-022021-005485-A	<1	FT-FY21-022021-005485-B	<1
WS- 005486	5/14/2020	5/14/2021	2	Cooler	In hallway across from elevator	Low Right	WF-05142020-005486	3/10/2021	FT-FY21-022021-005486-A	<1	FT-FY21-022021-005486-B	<1
WS- 005491	5/14/2020	5/14/2021	1	Cooler	In hallway adjacent to gym 115	High Left	WF-05142020-005491	3/10/2021	FT-FY21-022021-005491-A	<1	FT-FY21-022021-005491-B	<1
WS- 005492	5/14/2020	5/14/2021	1	Cooler	In hallway adjacent to gym 116	Low Right	WF-05142020-005492	3/10/2021	FT-FY21-022021-005492-A	<1	FT-FY21-022021-005492-B	<1

## Food Prep Sink

Less than 5ppb - Devices requiring no remediation												
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location		Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 005480	1/8/2021	1/8/2022	1	Food Prep Sink	In pantry room 114		WF-01082021-005480	3/10/2021	FT-FY21-022021-005480-A	<1	FT-FY21-022021-005480-B	<1